

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. W 39828

UNIQUE WELL I.D. #

Water Right Permit No. 29/3E/15-R

(1) OWNER: Name Gary Whitcomb Address 3847 S. Bells Beach, Langley, Wa. 98260

(2) LOCATION OF WELL: County Island SE 1/4 SE 1/4 Sec 15 T 29 N. R 3E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) 5770 S. Langley Rd. Langley Wa. 98260

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐
☐ Irrigation ☐ Test Well ☐ Other ☐
☐ DeWater ☐

(4) TYPE OF WORK: Owner's number of well (if more than one)
Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 314 feet. Depth of completed well 314 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 ft. Diam. from 2 ft. to 309 ft.
Welded ☒ Diam. from _____ ft. to _____ ft.
Liner installed ☐ Threaded ☐ Diam. from _____ ft. to _____ ft.

Perforations: Yes ☐ No ☒

Type of perforator used _____

SIZE of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

Screens: Yes ☒ No ☐

Manufacturer's Name Houston Screen Company

Type Stainless Steel Model No. _____

Diam. 5 Slot size .010 from 309 ft. to 314 ft.

Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel _____

Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.

Material used in seal Bentonite

Did any strata contain unusable water? Yes ☒ No ☐

Type of water? too little Depth of strata 160

Method of sealing strata off Cased by it.

(7) PUMP: Manufacturer's Name Flint & Walling

Type: Submersible H.P. 2

(8) WATER LEVELS: Land-surface elevation above mean sea level _____ ft.

Static level 285 ft. below top of well Date 8/1/94

Artesian pressure _____ lbs. per square inch Date _____

Artesian water is controlled by _____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☐ If yes, by whom? _____

Yield: 20 gal./min. with 10 ft. drawdown after 2 hrs.

" " " "

" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time Water Level Time Water Level Time Water Level

Date of test _____

Bailer test 15 gal./min. with 7 ft. drawdown after 1 hrs.

Airstest _____ gal./min. with stem set at _____ ft. for _____ hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water _____ Was a chemical analysis made? Yes ☒ No ☐

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
Gravelly clay: brown, dry.	0	18
Sand & gravel: brown, dry.	18	30
Sand: brown, dry.	30	155
Clay: gray.	155	158
Sand: coarse, gray. Water.	158	162
Sand: gray, very fine. Water	162	168
Silty: gray. Water.	168	195
Clay: gray.	195	198
Sand & gravel: gray, dry.	198	200
Clay: gray.	200	220
Sandy clay: gray.	220	230
Clay: gray.	230	250
Silty clay: gray, saturated.	250	275
Clay: gray.	275	285
Sand: gray, WXX Water.	285	290
Sand: gray/brown, chunks of clay. Tight.	290	300
Sand & small gravel: gray. Water.	300	305
Sand: gray, fine, brown water	305	310
Sand: gray, fine, clean.	310	314
Sand: gray, wood chips, clay colored water.	314	

This well site meets all Island County codes (3.08) for siting a single family well. Velocity of property lines remains with the owner.

John R. [Signature] #0852

Work Started July 7 94 19. Completed Aug. 8 19 94

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME Cable Tool Well Drilling Company
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address 11723 194th Ave NE Redmond, Wa.

(Signed) *John R. [Signature]* License No. 0852
(WELL DRILLER)

Contractor's Registration No. CABLETW 13203 Date Aug. 15 19 94

(USE ADDITIONAL SHEETS IF NECESSARY)